MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

Moore Bayou Water Association

Public Water System Name

0140012, 0140051, 0140052

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION *(Check all boxes that apply.)*

INDIRECT DELIVERY METHODS *(Attach copy of publication, water bill or other)*	DATE ISSUED
☑ Advertisement in local paper *(Attach copy of advertisement)*	5-20-21
☑ On water bills *(Attach copy of bill)*	5-27-21
☐ Email message *(Email the message to the address below)*	
☐ Other _____	
DIRECT DELIVERY METHOD *(Attach copy of publication, water bill or other)*	**DATE ISSUED**
☐ Distributed via U. S. Postal Mail	
☐ Distributed via E-Mail as a URL *(Provide Direct URL):* _____	
☐ Distributed via E-Mail as an attachment	
☐ Distributed via E-Mail as text within the body of email message	
☑ Published in local newspaper (attach copy of published CCR or proof of publication)	
☐ Posted in public places (attach list of locations)	
☐ Posted online at the following address *(Provide Direct URL):* _____	

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Jackie Wiley,	Clerk	5-26-21
Name	Title	Date

SUBMISSION OPTIONS *(Select one method ONLY)*

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800 (NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2020 Annual Drinking Water Quality Report
Moore Bayou Water Association, Inc.
PWS#: 0140012, 0140051 & 0140052
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Moore Bayou Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Thomas E. Clayton, Jr. 662.326.3322. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meeting. They are held on the third Tuesday of each month at 6:00 PM at the Thomas Clayton Office in Marks, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st , 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

PWS ID #: 0140012 **TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2020	2.6	No Range	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.0087	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	2.4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2018/20	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.347	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2020	7.7	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2019*	210000	No Range	PPB	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2018*	18	0 - 11	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	38	0 – 71	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	.7	.5 -.8	ppm	0	MRDL = 4	Water additive used to control microbes

PWS ID #: 0140051 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2020	1.9	No Range	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.0087	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	1.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20*	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.349	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2020	6.1	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
Chlorine	N	2020	.7	.5 -.8	ppm	0	MRDL = 4	Water additive used to control microbes

PWS ID #: 0140052 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2020	1.8	No Range	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and

								electronics production wastes
10. Barium	N	2020	.0184	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	1.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.463	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2020	7.8	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	2019*	290000	No Range	PPB	NONE	NONE	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2020	35	5 - 61	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	Y	2020	164	81.5 - 190	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	.7	.5 - .8	ppm	0	MRDL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2020.*

Disinfection By-Products:

(82) Total Trihalomethanes (TTHMs). Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

We routinely monitor for the presence of drinking water contaminants. The water supplied from system #0140052 presented high levels of TTHM in all quarters of 2020. The system has added more chlorine and continue to flush the lines regularly and plan to connect to the original system.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Moore Bayou Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

The Clarksdale
Press Register

128 East Second Street, Clarksdale, MS 38614
Phone 662-627-2201, www.pressregister.com

Proof of Publication

STATE OF MISSISSIPPI
COUNTY OF COAHOMA

Personally appeared before me, a Notary Public in and for said County and State, the publisher, general manager, or his undersigned agent, of a newspaper, printed and published in the City of Clarksdale, in the county and state aforesaid, called **The Clarksdale Press Register,** who being duly sworn, deposed and said that the publication of a notice of which a true copy is hereto affixed, has been made in said paper for the period of 1 weeks consecutively to-wit:

In Vol. 156 No. 19, dated the 12th day of May, 2021

In Vol. _____ No. _____, dated the _____ day of _____, _____

In Vol. _____ No. _____, dated the _____ day of _____, _____

In Vol. _____ No. _____, dated the _____ day of _____, _____

In Vol. _____ No. _____, dated the _____ day of _____, _____

and that **The Clarksdale Press Register** has been published for a period of more than one year.

Sworn to and subscribed before me, this 12th day of May, 2021

STATE OF MISSISSIPPI NOTARY PUBLIC (SEAL) ID # 116202 BRENDA A. KELLER Commission Expires Oct. 27, 2024 COAHOMA COUNTY

Brenda A Keller
Notary Public

My Commission Expires: Oct. 27, 2024

To: Moore Bayou Water Assoc.

for taking the annexed publication of 64"

~~words~~ or the equivalent thereof for a total of 1

times $40.00, plus $3.00 for making each proof (2)

of publication and deposing to same for a total cost of $646.00.

Sandra R. Hite
Designated Agent
For the Clarksdale Press Register

SPORTS

Stringer— Continued from Page 12

Towner declined to comment about Stringer's employment and the next step to find a new coach.

In the video Thursday, Stringer thanked God for opportunity to be at CCC for six years. He played basketball for CCC, graduated from Coahoma County High School in 1994, was the Oakhurst Middle School principal and coached in several capacities in the Clarksdale Municipal School District and then-Coahoma Agricultural High School. He talked about how he worked in community for 20 years total.

"At this point, I think it's time for me to change chapters," Stringer said. "I think it's time for me to move forward. At this time, someone has made a recommendation saying they want me to resign from my job duties at Coahoma Community College and I just want to say thank God for all the opportunity. Normally, in the past, I'd probably be all upset and disgruntled and things like that. But I started looking at it where God is taking me. Sometimes in life you've just got to move on. Sometimes you just go where God wants you to go."

Stringer said he has put everything in God's hands.

"Like a young black man like me, I came from the project to the Pinnacle," said Stringer, who grew up in a one-parent home.

Stringer said he is thankful and blessed to be position in, thanked everyone for their support and blessed those who did not support him. Speaking to the administration, he said prayed and hope things improved. He praised the job CCC women's basketball coach Stephanie Murphy, women's assistant basketball coach Isaiah Butler and head football coach Travis Macon have done to improve the athletic program.

Stringer said the men's basketball program did not win a game the year before he took over and he is leaving the program better than he found it.

"All the kids that have graduated, all the kids that are former players that have worked hard for me, I'm just really blessed and thankful that God entrusted me and their parents entrusted me to help lead and guide them for the years that I have guided them," Stringer said.

Stringer said the last three years the CCC men's basketball team had a 93 percent graduation rate along with the highest GPA on campus at one point at 2.9. He added God placed something inside him to encourage and motivate kids to do better.

We're pleased to present to yo
services we deliver to you every
understand the efforts we mak
ensuring the quality of your wat

The source water assessment
supply to identified potential so
made has been furnished to
Association have received a low

If you have any questions about
valued customers to be informe
are held on the third Tuesday of

We routinely monitor for contam
contaminants that we detected
the table reflects the most recen
in some cases, radioactive ma
microbial contaminants, such a
operations, and wildlife; inorgan
runoff, industrial, or domestic w
from a variety of sources such
synthetic and volatile organic ch
stations and septic systems; ra
activities. In order to ensure th
provided by public water syster
amounts of some contaminants
water poses a health risk.

In this table you will find many
provided the following definitions

Action Level - the concentratio
follow.

Maximum Contaminant Level (
MCLs are set as close to the MC

Maximum Contaminant Level G
or expected risk to health. MCL

Maximum Residual Disinfectant
addition of a disinfectant is nece

Maximum Residual Disinfectant
risk of health. MRDLGs do not r

Parts per million (ppm) or Milligr

Parts per billion (ppb) or Microgr

PWS ID #: 014001

Contaminant	Violation Y/N	C
Inorganic Contami		
8. Arsenic	N	20
10. Barium	N	20
13. Chromium	N	20
14. Copper	N	20
16. Fluoride	N	20
17. Lead	N	20
21. Selenium	N	20
Sodium	N	20
Disinfection By-Pro		
81. HAA5	N	20
82. TTHM [Total trihalomethanes]	N	20
Chlorine	N	20

PWS ID #: 0140051

Contaminant	Violation

The Quitman County Democrat

P.O. Box 328, Marks, MS 38646
Phone 662-326-2181
quitmancodemocrat@att.net

Proof of Publication

Bill Knight personally appeared before me. the undersigned authority in and for said County and State, and states under oath that he is the Publisher of The Quitman county Democrat, a newspaper published in the City of Marks, State and County aforesaid, and having a general circulation in said county, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper, the *Quitman County Democrat*, consecutive times, to wit:

Proof

Scheduled Dates to Run:

Volume No. ~~114~~ 115 on the 20 day of May, 2021
Volume No. 114 on the _____ day of _____, 2021
Volume No. 114 on the _____ day of _____, 2021
Volume No. 114 on the _____ day of _____, 2021

_____
AFFIANT

Sworn and subscribed before me this 20 day of May, 2021

BY: Vivian B. Norris

My Commission Expires, April 9, 2023

STATE OF MISSISSIPPI NOTARY PUBLIC ID # 15409 VIVIAN B. NORRIS Commission Expires April 9, 2023 QUITMAN COUNTY

THIS IS YOUR INVOICE
PLEASE PAY UPON RECEIPT

Bill To: Moore Water Assn
Marks, MS

Single First Insertion of _____ Words @ .12 $_____
Week 2 Insertion of _____ Words @ .22 $_____
Week 3 Insertion of _____ Words @ .32 $_____
Week 4 Insertion of _____ Words @ .42 $_____

Publications bill by Column inch
1 Times Run 3 x 20 x $9.00 per column inch $ 540.00

Proof of Publication Fee - $3.00 per 1 proof/s $ 3.00

TOTAL PUBLICATION FEE $ 543.00

2020 Annual Drinking Water Quality Report
Moore Bayou Water Association, Inc.
PWS#: 0140012, 0140051 & 0140052
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Moore Bayou Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Thomas E. Clayton, Jr. 662.323.3222. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meeting. They are held on the third Tuesday of each month at 6:00 PM at the Thomas Clayton Office in Marks, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this below you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

PWS ID #: 0140012 **TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2020	2.6	No Range	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2020	.0067	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020	2.4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2020	.347	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	N	2020	7.7	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Nitrate	N	2019*	210003	No Range	PPB	0	0	Runoff Soil, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2019*	18	0 - 11	ppb	0	60	By-Product of drinking water disinfection
82. TTHM [Total trihalomethanes]	N	2019*	38	0 – 73	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	.7	.5 -.9	ppm	0	MRDL = 4	Water additive used to control microbes

PWS ID #: 0140051 **TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples	Unit Measure	MCLG	MCL	Likely Source of Contamination

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
020006600	04/15	05/15

SERVICE ADDRESS

EMERALD RD

METER READINGS CURRENT	PREVIOUS	USED
591	591	

CHARGE FOR SERVICES

WTR	24.50
PAST DUE	2.00
NET DUE >>>	26.50
SAVE THIS >>	
GROSS DUE >>	26.50

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
26.50	.00	26.50

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

020006600
DUBLIN FIRE DEPT

PO BOX 579
CLARKSDALE MS 38614-0579

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
020006650	04/15	05/15

SERVICE ADDRESS

1420 EMERALD RD

METER READINGS CURRENT	PREVIOUS	USED
31551	31400	151

CHARGE FOR SERVICES

WTR	24.50
TAX	1.72
PAST DUE	2.80
NET DUE >>>	29.02
SAVE THIS >>	2.80
GROSS DUE >>	31.82

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
29.02	2.80	31.82

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

020006650
LUCKETT PUMP & WELL SERVICE, I

1420 EMERALD ROAD
TUTWILER, MS 38963

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
020006700	04/15	05/15

SERVICE ADDRESS

1445 EMERALD RD

METER READINGS CURRENT	PREVIOUS	USED
60206	60061	145

CHARGE FOR SERVICES

WTR	24.50
NET DUE >>>	24.50
SAVE THIS >>	2.45
GROSS DUE >>	26.95

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
24.50	2.45	26.95

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

020006700
EULA H LUCKETT

1445 EMERALD RD
TUTWILER, MS 38963

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010012350	04/15	05/15

SERVICE ADDRESS

METER READINGS CURRENT	PREVIOUS	USED
7041	7039	2

CHARGE FOR SERVICES

WTR	19.00
TAX	1.33
PAST DUE	1.18
NET DUE >>>	21.51
SAVE THIS >>	2.17
GROSS DUE >>	23.68

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
21.51	2.17	23.68

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010012350
AIR-WORTHY, INC

20 AIRPORT RD
LYON MS
38645

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010012430	04/15	05/15

SERVICE ADDRESS

AIRPORT-FLETCHER F

METER READINGS CURRENT	PREVIOUS	USED
18550	18514	36

CHARGE FOR SERVICES

WTR	19.00
TAX	1.33
PAST DUE	2.17
NET DUE >>>	22.50
SAVE THIS >>	2.17
GROSS DUE >>	24.67

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
22.50	2.17	24.67

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010012430
FOSTER, FLOWD W.

159 HIGHWAY 61 JONESTOWN RD
COAHOMA MS 38617-9539

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010012450	04/15	05/15

SERVICE ADDRESS

METER READINGS CURRENT	PREVIOUS	USED
210761	210422	339

CHARGE FOR SERVICES

WTR	25.60
TAX	1.79
PAST DUE	7.83
NET DUE >>>	35.22
SAVE THIS >>	2.93
GROSS DUE >>	38.15

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 22
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
35.22	2.93	38.15

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010012450
FOSTER, FLOYD W.

159 HIGHWAY 61 JONESTOWN RD
COAHOMA MS 38617-9539

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010045200	04/15	05/15

SERVICE ADDRESS
1555 WHITING ROAD

METER READINGS CURRENT	PREVIOUS	USED
71190	68467	2723

CHARGE FOR SERVICES

WTR	138.84
GRB	16.00
PAST DUE	122.85
NET DUE >>>	277.69
SAVE THIS >>	23.60
GROSS DUE >>	301.29

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS M
U.S. POSTAGI
PAID
PERMIT NO. 2
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
277.69	23.60	301.29

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010045200
STEVE BAILEY

1485 WHITING RD
MARKS MS 38646
38646

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010045240	04/15	05/15

SERVICE ADDRESS
114 WHITING LAKE DRIVE

METER READINGS CURRENT	PREVIOUS	USED
77321	77297	24

CHARGE FOR SERVICES

WTR	57.00
GRB	32.00
NET DUE >>>	89.00
SAVE THIS >>	5.70
GROSS DUE >>	94.70

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS M
U.S. POSTAGE
PAID
PERMIT NO. 2
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
89.00	5.70	94.70

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010045240
MARKS DUCK CLUB, LLC
C/O THOMAS CLAYTON
P.O. BOX 301
MARKS, MS 38646

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-25951

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010045250	04/15	05/15

SERVICE ADDRESS
4510 REGAL ROAD

METER READINGS CURRENT	PREVIOUS	USED
62794	62374	420

CHARGE FOR SERVICES

WTR	29.45
GRB	16.00
NET DUE >>>	45.45
SAVE THIS >>	2.95
GROSS DUE >>	48.40

RETURN THIS STUB WITH PAYMENT TO:
MOORE BAYOU WATER ASSN
P.O. BOX 374
MARKS, MS 38646

PRESORTED
FIRST-CLASS M/
U.S. POSTAGE
PAID
PERMIT NO. 2
MARKS, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2021	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
45.45	2.95	48.40

CCR AVAILABLE UPON REQUEST

RETURN SERVICE REQUESTED

010045250
THELMA MILLICAN

4510 REGAL RD
MARKS MS 38646-9272